



Tentative Interim Amendment

NFPA 13R

Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height

2010 Edition

Reference: 4.7 and 5.4.3

TIA 10-1

(SC 10-8-19/TIA Log #995)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, 2010 edition. The TIA was processed by the Technical Committee on Residential Sprinkler Systems and the Technical Correlating Committee on Automatic Sprinkler Systems, and was issued by the Standards Council on August 5, 2010, with an effective date of August 25, 2010.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. *Add new sections as follows:*

4.7 Antifreeze Systems. Antifreeze shall not be permitted within the dwelling unit portions of sprinkler systems.

5.4.3 Antifreeze shall not be permitted within the dwelling unit portions of sprinkler systems.

2. *Renumber 5.4.3 as 5.4.4.*

Issue Date: August 5, 2010

Effective Date: August 25, 2010

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/codelist)

Copyright © 2010 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION